Himachal Pradesh
Jal Shakti Vibhag

No. AE-IPH-SDS-N.O.C.-2026- 585 Dated: - 4/07/026

TO WHOME IT MAY CONCERN

Certified that Sh. Kishori Lal S/o Sh. Dagu Ram VPO Kotli Tehsil Kotli Distt. Mandi is the consumer of Jal Shakti Vibhag having account No. L-36. The water is supplied to the consumer for Oxford School, Kotli VPO Kotli Tehsil Kotli Distt. Mandi (H.P.). The water supplied by the department is safe for drinking.

This certificate is issued with the condition that the consumer will ensure timely cleaning and safe keeping of storage tank and will be solely responsible for any kind of tampering.

Dated:- 30.06.2026

Assistant Engineer
Jal Shakti Sub Division
Saigaloo

Himachal Pradesh Jal Shakti Vibhag
Water Testing Laboratory, Motipur, Mandi (H.P.)

Lab Ref. No. MDPB/1015 GR No. 1610148

Name and Address of Sender.... Director Oxford School Kotli Distt. Mandi (H.P.)

Division.... — Sub-Division.... —

Section.... — Name of District: Mandi

Name of Block... Mandi Sadar Name of Panchyat.... Kotli

Name of Village.... Kotli Name of Habitation(s).. Oxford School Kotli

Name of Scheme and Location of Source... W.S.S Jaral Kotli Oxford School Kotli Distt Mandi (H.P.)

Type of Source: Scheme source / Delivery Point / Stand Post / Surface Water / Private / Public.

Date & Time of Receipt at Laboratory.... 24/06/2026

Report Issue Date ... 27/06/2026

Type of Sample: Raw Water / Borewell / Filtered Water / Chlorinated Water / Distributed System / Hand Pump

Limits :**Based upon BIS : 10500-2012**

(A) PHYSICAL PARAMETER

S.No.	Test Parameter	Units	Acceptable Limit	Permissible limits[in the absence of alternate source]	Result
1.	Temperature	°C	-	-	22.2°C ± 2°C

(B) MICROBIOLOGICAL PARAMETER

2.	Total Coliforms	Number/100ml	Nil	Nil	Nil
3.	E. coli / Thermo tolerant coli-forms	Number/100ml	Absent	Absent	Absent

NOTE: Indicate discrete sampling. Water qualities monitoring to be continued only if these are traced in drinking water sources.

Remarks The Analyzed water Sample shows absence of E.coli and Total Coliform Bacteria, indicating that the water is free from fecal contamination and is considered Microbiologically Potable as per Standard Guidelines.

Microbiologist
Jal Shakti Vibhag
Water Testing Lab. Mandi (H.P.)

Junior Engineer
Jal Shakti Vibhag
Sub-Division-Mandi(H.P.)

Assistant Engineer
Jal Shakti Vibhag
Sub-Division-Mandi(H.P.)

Water Testing Laboratory,
Motipur, Mandi (H.P.)

TC-17036

TEST REPORT

Sample No: 3576	**Report Issue Date :** 25/06/2026
Environmental Condition: Temperature 22.2°C±2°C	**Relative Humidity:** 53%

Test Report No.: MDP/964
Name & Address Of Customer: Director Oxford School Kotli Distt Mandi (H.P.)
Sampling Method: IS/APHA
Sample Description: Drinking Water
Sample Quantity: 2lt.
Collected on: 24/06/2026
Test Start Date: 24/06/2026
Test End Date: 24/06/2026

Condition of Sample When Received: Good
Name of Source/Scheme: W.S.S. Jaral Kotli
Name of Panchayat: Kotli
Name of Habitation: Oxford School Kotli
Name of Village: Kotli
Type of Source: Treated Water
Sample Submitted By: Shweta Verma

Sr. No.	Test	Test Method	Result	Units	Requirement as per IS 10500:2012	
					Acceptable limit	Permissible limit in absence of alternate source
		Physical Parameter				
1	pH	IS-3025(PART-11) : 2022(ISO 10523:2008) Electrometric method	7.68 at temp. 22.2°C±2C		6.5-8.5	No Relaxation
2	Color	APHA24th Edition 2120 (Method-B) (Visual comparison method)	5	Hazen Unit	5 H.U.	15 H.U.
3	Odor	IS 3025(Part-5) 2018	Agreeable	Qualitative	Agreeable	Agreeable
4	Taste	IS 3025(Part-8) 2023	Agreeable	Qualitative	Agreeable	Agreeable
5	Turbidity	APHA 24 th Edition (Part-C) Nephlometric method	2.3	N.T.U.	1 NTU Max	5 NTU Max
		Chemical Parameter				
6	Total hardness as $CaCO_3$	IS-3025 (PART-21)-2009,Reaff.2019,2023EDTA Titration Method	108	Mg/l	200mg/l Max	600mg/l Max
7	Total Alkalinity as $CaCO_3$	IS-3025 (PART-23) 2023 Indicator method	122	Mg/l	200mg/l Max	600mg/l Max
8	Chloride	IS :3025 (PART-32)-1988, Reaff.2019 Argentometric method	18.99	Mg/l	250mg/l Max	1000mg/l Max
9	Total Dissolved Solids (TDS)	APHA 23rd Edition 2540-(Part-C)Total Dissolved solids (Dried at 180 degree Celsius)	165	Mg/l	500mg/l Max	2000mg/l Max
10	Calcium as Ca	APHA 24th Edition 3500-Ca Method B (EDTA Titremetric method)	29.66	Mg/l	75mg/l Max	200mg/l Max
11	Magnesium as Mg	APHA 24 th Edition 3500Mg-B (Calculation method)	8.26	Mg/l	30mg/l Max	100mg/l Max

Note:
- Test report should not be produced partly or full for any purpose without approval of signatory authority for legal purpose.
- The results refer only to tested samples and parameters tested.
- The samples will be stored for a period of 7 days from the date of issue of report.

----------END OF REPORT----------

Reviewed By :- Aparajita
Authorised Signatory
Water Testing Laboratory
Motipur, Mandi (H.P.)

Aparajita
Authorized Signatory
Water Testing Laboratory
Motipur, Mandi (H.P.)

Aparajita
Authorised Signatory
Water Testing Laboratory
Motipur, Mandi (H.P.)

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated:

No.

It is certified that an inspection team headed by Assistant Engineer, Jal Shakti Vibhag Sub-Division Saigaloo Mandi (H.P.)
(Name of Officers with designation) from Jal Shakti Vibhag Mandi HED

inspected the Oxford School Kotli Mandi (H.P.)

(Name & Address of the school) on 27-07-2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. MDP/964, MDPB/1015 dated 25/06/2026 to 27/06/2026

of Water Testing Laboratory Motipur Mandi (H.P.) (PHED Lab) certified that the

Oxford School Kotli (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 25-December-2026

Junior Engineer
Jal Shakti Section Kotli
Sub-Division Saigaloo

Signature with Seal: .....
Name : Er. Rajinder Thakur
Designation : Assistant Engineer
Name & Address of the Office / Department : Jal Shakti Vibhag

Assistant Engineer
JSV Sub Division
Saigloo

To
Principal
Oxford School Kotli
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Principal
Oxford School
Kotli, Mandi (H.P.)

Oxford School
Director
Kotli Distt. Mandi (H.P.)